



[Careers](#) [News](#) [Contact Us](#)
[Home](#) » [Services](#) » [Testing & Certification](#) » [Certified Product Listing](#) » [Certificate Record](#)

## Certificate Record

Customer	Class	File Number
Kuo Yuh Enterprise Co. No. 17 Ke Chia 6th Road, Tou Liu City Youn Lin County Taiwan 64057	3215-30 SUPPLEMENTARY PROTECTORS- COMPONENT ACCEPTANCE PROGRAM	102199_0_000

### Quick Links

[Certification Marks and Labels](#)  
[Certified Product Listing](#)  
[CSA Communities](#)  
[Request a Quote](#)

**NOTE:** PRODUCTS EVALUATED TO CSA NOTICE N04-042.

Supplementary Protector, thermal trip, manual reset, without manual switching feature:

- Model F88-1500, rated 15A, 125V ac; Model F88-1300, rated 13A, 125V ac;

Application Codes: TC2. OL0, SC: C1, 1kA, 125V ac (4In Series fuse)

Supplementary Protector, thermal trip, single pole, auto reset:

- Model F66, rated 0.5A to 5A, 125V ac;

Application Codes: TC2. OL0, SC: C1, 0.2kA, 125V ac (4In Series fuse)

Supplementary Protector, thermal trip, manual reset, without manual switching feature:

[ABOUT](#)
[SERVICES](#)
[INDUSTRIES](#)

- Series 88, rated 15A, 125V ac and 10A, 125V ac/50V dc;

Application Codes: TC2, OL0, SC: C1, 1kA, 125V ac and SC: C1, 0.03 kA, 50V dc (4In Series fuse)

Supplementary Protector, thermal trip, manual reset:

- Series 88, rated 3A to 16A, 125 V ac;

Application Codes: TC1, OL1, SC: U3, 0.4KA, 125V ac

Supplementary Protector, thermal trip, manual reset:

- Series 98, rated 3A to 30A, 125 V ac;

Application Codes: TC1, OL1, SC: U3, 0.4KA, 125V ac

Notes:

1. Accepted only for use as components of other certified assemblies where the suitability is determined by CSA International.
2. The F66 devices are intended to be mounted on printed wiring boards.
3. The terminals of the device have not been investigated for field wiring.
4. These devices are not suitable for branch circuit overcurrent protection.
5. All short circuit testing was conducted with series protection rated 20 A for F66 Series.
6. Cat No 88, rated 15 A and 10 A, 125 V ac, has a short circuit withstand rating of 1000 A.
7. Cat No 88, rated 10 A, 50 V dc, has a short circuit withstand rating of 30 A.

**CSA Group Web Sites**

CSA Group  
Bayern GmbH

CSA Group  
Seattle

**CSA Group Sites**

CSA  
Communities

CSA Registries  
OHS Portal

**Information For...**

Manufacturers  
Members  
Government,  
Regulators &  
AHJs

**Corporate**

Privacy  
Terms of Use  
Service  
Agreement

**About CSA Group**

CSA Group is an independent, not-for-profit member-based association dedicated to advancing safety, sustainability and social good. We are an internationally-accredited standards development and testing & certification organization. We also provide consumer product evaluation and